

DEPARTMENT OF LABOR AND ECONOMIC GROWTH

DIRECTOR'S OFFICE

CONSTRUCTION CODE

Filed with the Secretary of State on.
These rules take effect

(By authority conferred on the director of the department of labor and economic growth by section 4 of 1972 PA 230, MCL 125.1504, and Executive Reorganization Order Nos. 1996-2 and 2003-1, MCL 445.2001 and 445.2011)

R 408.30801, R 408.30808, R 408.30809, R 408.30810, R 408.30812, R 408.30818, R 408.30819, R 408.30823, R 408.30826, R 408.30835, R 408.30867, R 408.30868, R 408.30869 and R 408.30873 of the Michigan Administrative Code are amended and R 408.30834, is added to the Code as follows:

PART 8. ELECTRICAL CODE

R 408.30801 National electrical code; adoption by reference; inspection; purchase.

Rule 801. The standards contained in the national electrical code, 2002~~5~~ edition, except sections ~~80.2, 80.5, 80.7, 80.17, 80.27, 80.29, 80.31, 80.33, 80.35, 90.1, 90.5, and~~ **501.30B, 502.30B, 503.30B, 505.25B, 506.25B**, 547.1 to 547.10, and Annex G, as published by the national fire protection association, shall govern the installation, replacement, alteration, relocation, and use of electrical systems or material. With the exceptions noted, the national electrical code is adopted in these rules by reference. Fine print notes contained within the body of the code are not adopted as a part of the code. All references to the ANSI/ASME A17.1-~~1996~~**2004**, Safety Code for Elevators and Escalators means the Michigan Elevator Code and all references to the National Electrical Code means the Michigan Electrical Code. The code is available for inspection at the Okemos office of the **Michigan** department of labor and economic growth, bureau of construction codes and fire safety. The National Electrical Code may be purchased from the National Fire Protection Association, Batterymarch Park, Quincy, Massachusetts 02269, or from the Michigan Department of Labor and Economic Growth, Bureau of Construction Codes and Fire Safety, 2501 Woodlake Circle, Okemos, Michigan 48864, at a cost as of the time of adoption of these rules of ~~\$60.00~~**72.50** each.

R 408.30808 Scope.

Rule 808. Sections 80.1, ~~of the code is amended and~~ 80.1.1, 80.1.2, and 80.1.3 are added to the code to read as follows:

80.1. Scope. The code regulates the design, installation, maintenance, alteration, and inspection of electrical systems including all wiring, fixtures, appliances, and appurtenances in connection with the utilization of electrical energy, within or on a building, structure, or properties, and including service entrance wiring as defined by the code.

May 15, 2006

Exception: Electrical wiring and equipment within 1- and 2-family dwellings shall be constructed, installed, and maintained in accordance with the Michigan residential code.

80.1.1. Intent. The purpose of the code is to provide minimum standards to safeguard life or limb, health, property, and public welfare by regulating and controlling the design, construction, installation, quality of materials, location, operation, and maintenance or use of electrical wiring and equipment.

80.1.2. Severability. If a section, subsection, sentence, clause, or phrase of the code is, for any reason, held to be unconstitutional, such decision shall not affect the validity of the remaining portions of the code.

80.1.3. Code conformity required. A person shall not install, alter, maintain, service, or repair, or cause or permit the installation, altering, maintaining, servicing, or repairing of electrical equipment in or on any building, structure, or part thereof, or on any premises, if by the person's action the work does not conform to the provisions of the code.

R 408.30809 Purpose.

Rule 809. Section 80.3 ~~of the code is amended~~ **added to the code** to read as follows:

80.3. Purpose. The purpose of this article shall be to provide requirements for administration and enforcement of the Michigan electrical code.

R 408.30810 Authority.

Rule 810. Section 80.13 ~~of the code is amended~~ **added to the code** to read as follows:

80.13. Authority. Where used in the code, "authority having jurisdiction" means the enforcing agency in accordance with 1972 PA 230, MCL 125.1501 et seq., as defined in R 408.30828. The code shall be administered and enforced by the enforcing agency in accordance with 1972 PA 230, MCL 125.1501 et seq.

R 408.30812 Means of Appeal.

Rule 812. Sections 80.15 ~~of the code is amended~~ and 80.15.1 ~~is~~ **are** added to the code to read as follows:

80.15. Means of appeal. A person may appeal a decision of the enforcing agency to the board of appeals. An application for appeal shall be based on a claim that the true intent of the code or the rules governing construction have been incorrectly interpreted, the provisions of the code do not apply, or an equal or better form of construction is proposed. The application shall be filed under section 14 of 1972 PA 230, MCL 125.1501 et seq.

80.15.1. Limitation of authority. The board of appeals shall have no authority relative to interpretation of the administration of the code nor shall such board be empowered to waive requirements of the code.

R 408.30818 Permits and certificates.

Rule 818. Sections 80.19, ~~of the code is amended and~~ 80.19.1, 80.19.2, 80.19.3, 80.19.4, 80.19.5, 80.19.6, 80.19.7, and 80.19.8 are added to the code to read as follows:

80.19. Permits and certificates. A person shall not equip a building with electrical conductors or equipment or make an alteration of, change in, or addition to, electrical conductors or equipment without receiving a written permit to do the work described. If the electrical installation or alterations of, changes in, or addition to, electrical conductors or equipment are found to be in compliance with the provisions of the code and if the work has

passed the inspection of the enforcing agency, then the enforcing agency shall, upon the request of the permit holder to whom the permit was issued, issue a certificate of final electrical inspection. The certificate certifies that the provisions of the code have been complied with. This section does not apply to installations that are referred to in section 7(3)(a), (b), (c), (d), (e), (f), (h), (k), (l), or (n) of 1956 PA 217, MCL 338.887(3)(a), (b), (c), (d), (e), (f), (h), (k), (l), or (n).

80.19.1. To whom permits are issued. (1) To obtain an electrical permit, an applicant shall be 1 of the following:

(a) A holder of an electrical contractor license or the qualifying master for the electrical contractor when authorized by the electrical contractor to secure a permit.

(b) A person, firm, or corporation holding an affidavit as provided by R 338.1039a.

(c) A homeowner who occupies or will occupy a single-family dwelling and other accessory structures located on the same lot intended for use by the homeowner for which the permit is obtained and who will install the electrical equipment as certified by the homeowner on the permit application in accordance with section 10(4) of 1972 PA 230, MCL 125.1510(4).

(2) To obtain a permit for a fire alarm system, as defined in section 1a(1) of 1956 PA 217, MCL 338.881a (1), an applicant shall be 1 of the following:

(a) A holder of an electrical contractor license.

(b) A holder of a fire alarm specialty contractor license or the qualifying fire alarm specialty technician qualifying the fire alarm specialty contractor when authorized by the fire alarm specialty contractor to secure a permit.

(c) A homeowner qualifying under section ~~80-19.180.19.1~~(1)(c) of the code.

(3) To obtain a permit for an electrical sign or outline lighting, as defined in section 1b(1) and (2) of 1956 PA 217, MCL 338.881b(1) and (2), an applicant shall be 1 of the following:

(a) A holder of an electrical contractor license.

(b) A holder of a sign specialty contractor license or the sign specialty technician qualifying the sign specialty contractor when authorized by the sign specialty contractor to secure a permit.

(c) A homeowner qualifying under section 80.19.1(1)(c) of the code.

(4) To obtain a permit for electrical wiring associated with the installation, removal, alteration, or repair of a water well pump on a single-family dwelling to the first point of attachment in the house from the well, an applicant shall be 1 of the following:

(a) A holder of an electrical contractor license.

(b) A registered pump installer under part 127 of 1978 PA 368, MCL 333.12701 to 333.12771.

(c) A homeowner qualifying under section 80.19.1(1)(c) of the code.

(5) To obtain a permit for wiring associated with existing mechanical and plumbing systems referenced in section 7(3)(i) of 1956 PA 217, MCL 338.887(3)(i), a person shall be 1 of the following:

(a) A holder of an electrical contractor license or the qualifying master for the electrical contractor when authorized by the electrical contractor to secure a permit.

(b) A holder of a mechanical contractor license issued in accordance with section 6(3)(a), (b), (d), (e), and (f) of 1984 PA 192, MCL 338.976(3)(a), (b), (d), (e), and (f).

(c) A holder of a plumbing contractor license issued in accordance with 2002 PA 733, MCL 338.3511 et seq.

(6) To obtain a permit for the installation of wiring associated with telecommunications equipment and related systems, an applicant shall be 1 of the following:

(a) A holder of an electrical contractor's license.

(b) A person, firm, or corporation primarily engaged in the telecommunications and related information systems industry.

(c) A homeowner qualifying under section 80.19.1(1)(c) of the code.

80.19.2 Application for permit. ~~To obtain an electrical permit, the applicant shall file the application in writing on a form furnished by the enforcing agency for that purpose. The application shall include all of the following:~~

~~-(1) A description of the work to be covered by the permit for which application is made.~~

~~-(2) Description of the land upon which the work is to take place by legal description, street address, or similar description that will readily identify and definitively locate the proposed building or work.~~

~~-(3) Be accompanied by construction documents in accordance with section 80.21 of the code.~~

~~-(4) Signature of the applicant.~~ **Each application for a permit, with the required fee, shall be filed with the code official on a form furnished for that purpose and shall contain a general description of the proposed work and its location. The contractor who is performing the work shall sign the application. The permit application shall indicate the proposed occupancy of all parts of the building and of that portion of the site or lot, if any, not covered by the building or structure and shall contain the information required by section 10 of 1972 PA 230, MCL 125.1510.**

80.19.3. Permit expiration. If work for which a permit is issued is not started within 6 months of the date of permit issuance or if work is abandoned for a period of 6 months, then the permit shall lapse and cease to be in effect. ~~The enforcing agency shall provide notice of this requirement to the permit holder.~~

80.19.4. Uncompleted installation notification. If a person to whom a permit is issued for the installation and inspection of electrical conductors and electrical equipment quits the installation for any reason, then the person shall notify the enforcing agency.

80.19.5. Inspection and refunds for partial installation. If an installation is partially completed, then a permit holder, upon quitting the installation, shall notify the enforcing agency and shall request an inspection. The inspector shall record the acceptance of, or violations against, the work installed on the permit record according to the findings of the inspector. The enforcing agency shall not grant a refund to the permit holder of the permit fee covering electrical equipment installed and inspected.

80.19.6. Owner notification to enforcing agency. If a permit holder quits an installation after the electrical equipment is installed and fails to notify the enforcing agency, then the building owner or his or her agent may notify the enforcing agency and request inspection. Upon inspection, the enforcing agency shall send the permit holder a notice of a violation. The owner may then secure another licensed contractor to proceed with the work if the new contractor is properly covered by a permit.

80.19.7. Transfer of permit. An electrical permit is not transferable.

80.19.8. Fraudulent application for permit. A permit that is issued in violation of the laws of this state or as a result of false or fraudulent information or misinterpretation of conditions is subject to revocation at the direction of the enforcing agency. The enforcing agency shall

notify the person holding the permit to appear and show cause why the permit should not be revoked. Failure to appear is sufficient grounds for revocation of the permit.

R 408.30819 Plans and specifications.

Rule 819. Sections 80.21, ~~of the code is amended and~~ 80.21.1 and 80.21.2 are added to the code to read as follows:

80.21. Plans and specifications. An applicant shall submit a detailed set of plans and specifications with the application for an electrical permit for any wiring or alteration to an electrical system if the system requires installation of electrical equipment that has an ampacity of more than 400 amperes for the service or feeder and if the calculated floor area in a building is more than 3,500 square feet. The enforcing agency may request plans for projects that include an unusual design. The electrical drawings shall include all of the following details:

- (a) Lighting layout.
- (b) Circuiting.
- (c) Switching.
- (d) Conductor and raceway sizes.
- (e) Wattage schedule.
- (f) Service location and riser diagram.
- (g) Load calculations.
- (h) A proposed method of construction that is drawn with symbols of a standard form.

All conductors are assumed to be copper unless otherwise stated in the plan. Specifications, when provided, shall also include the information listed in this rule. The selection of suitable disconnect and overcurrent devices to provide proper coordination and interrupting capacity for a wiring system is the responsibility of the designer. The enforcing agency, when approving electrical plans, does not assume responsibility for the design or for any deviations from any electrical drawings. The permit holder shall ensure that the plans and specifications approved by the enforcing agency, or a certified copy of the plans and specifications, where required, are available on the jobsite for the use of the enforcing agency.

80.21.1. Preparation of plans. An architect or engineer shall prepare, or supervise the preparation of, all plans and specifications for new construction work or repair, expansion, addition, or modification work. The architect or engineer shall be licensed under 1980 PA 299, MCL 339.101 et seq. The plans and specifications shall bear the architect's or engineer's signature and seal.

Note: For exceptions, see 1980 PA 299, MCL 339.101 et seq.

80.21.2. Review of construction documents. The enforcing agency shall review the application, construction documents, and other data filed by an applicant for a permit. If the enforcing agency finds that the proposed work conforms to the requirements of the code and related laws and ordinances and that the fees are paid, then the agency shall issue a permit to the applicant.

R 408.30823 Connection to electricity supply.

Rule 823. Section 80.25 ~~of the code is amended~~ **added to the code** to read as follows:

80.25. Connection to electricity supply. Except where work is ~~done~~**performed** under an annual permit or except as otherwise provided in the code, a person, firm, or corporation shall not make connection to a supply of electricity or to supply electricity to any electric

equipment installation for which a permit is required or that has been disconnected or ordered to be disconnected.

R408.30826 Violations.

Rule 826. Section 80.23 of the code is amended **added to the code** to read as follows:

80.23. Violations. If it is found that any electrical equipment does not conform to the provisions of the code, then the enforcing agency shall notify, in writing, the person who installs, or who is responsible for installing, the electrical equipment, in accordance with section 12(3) of 1972 PA 230, MCL 125.1512(3), of the defect, misuse, or violation.

Violations and penalties shall be as specified in section 23 of 1972 PA 230, MCL 125.1523.

R 408.30834 Maximum number of disconnects.

Rule 834. Section 230.71(A) of the code is amended to read as follows:

230.71(A). General. The service disconnecting means for each service permitted by section 230.2 of the code, or for each set of service-entrance conductors permitted by section 230.40, Exception Nos. 1, 2, 3, or 4, of the code, shall consist of not more than 6 switches or sets of circuit breakers, or a combination of not more than 6 switches and sets of circuit breakers, mounted in a single enclosure, in a group of separate enclosures, in a switchboard or on a switchboard. There shall be not more than 6 sets of disconnects per service grouped in any 1 location. For the purpose of this section, disconnecting means used solely for power monitoring equipment, transient voltage surge suppressors, or the control circuit of the ground-fault protection system or power-operable service disconnecting means, installed as part of the listed equipment, shall not be considered a service disconnecting means.

R 408.30835 Number of service-entrance conductor sets.~~Grounded and ungrounded conductor sources.~~

Rule 835.~~Section 300.3(b)(5) is added to the code to read as follows:~~

~~300.3(b)(5). Grounded and ungrounded conductor sources. Grounded and associated ungrounded circuit conductors for 2, 3, or 4 wire circuits shall all originate at the same source in the wiring system. A grounded conductor shall not be used for more than 1 multi-wire branch circuit.~~ Section 230.40 of the code is amended to read as follows:

230.40. Number of Service-Entrance Conductor Sets. Each service drop or lateral shall supply 1 set of service-entrance conductors.

Exception 1: A building may have 1 set of service-entrance conductors for each service, as defined in section 230.2 of the code, run to each occupancy or group of occupancies.

Exception 2: Where 2 to 6 service disconnecting means in separate enclosures are grouped at 1 location and supply separate loads from 1 service drop or lateral, 1 set of service-entrance conductors may supply each or several such service equipment enclosures.

Exception 3: A 2-family dwelling or a multifamily dwelling may have 1 set of service-entrance conductors installed to supply the circuits covered in section 210.25 of the code.

Exception 4: One set of service-entrance conductors connected to the supply side of the normal service disconnecting means may supply each or several systems covered by section 230.82(4) or section 230.82(5) of the code.

R 408.30867 Grounding **and bonding** of flexible metal conduit.

Rule 867. Section ~~350.14~~**348.60** of the code is amended to read as follows:

~~350.14~~**348.60.** ~~The permit holder shall not use flexible metal conduit as a grounding means. If an equipment bonding jumper is required around flexible metal conduit, then the permit holder shall install the jumper in accordance with section 250.102 of the code.~~ **An equipment grounding conductor or equipment bonding jumpers shall be installed. Equipment grounding conductors shall be installed in accordance with section 250.134(B) of the code. Equipment bonding jumpers shall be installed in accordance with section 250.102 of the code.**

R 408.30868 Grounding **and bonding** of liquidtight flexible metal conduit.

Rule 868. Section ~~350.13~~**350.60** of the code is amended to read as follows:

~~350.13~~**350.60.** ~~The permit holder shall not use liquidtight flexible metal conduit as a grounding means. If an equipment bonding jumper is required around liquidtight flexible metal conduit, then the permit holder shall install the jumper in accordance with section 250.102 of the code.~~ **An equipment grounding conductor or equipment bonding jumpers shall be installed. Equipment grounding conductors shall be installed in accordance with section 250.134(B) of the code. Equipment bonding jumpers shall be installed in accordance with section 250.102 of the code.**

R 408.30869 Grounding conductors.

Rule 869. Section 250.118 of the code is amended to read as follows:

250.118. Types of equipment grounding conductors. The equipment grounding conductor run with or enclosing the circuit conductors shall be 1 or more or a combination of the following:

- (1) A copper, aluminum, or copper-clad aluminum conductor. This conductor shall be solid or stranded; insulated, covered, or bare; and, in the form of a wire or a busbar of any shape.
- (2) Rigid metal conduit.
- (3) Intermediate metal conduit.
- (4) Electrical metallic tubing.
- (5) Flexible metallic tubing where the tubing is terminated in fittings listed for grounding and meeting both of the following conditions:
 - (a) The circuit conductors contained in the tubing are protected by overcurrent devices rated at 20 amperes or less.
 - (b) The length of flexible metallic tubing in the ground return path does not exceed 1.8m (6 feet).
- (6) Armor of type AC cable as provided in section 320.108 of the code.
- (7) The copper sheath of mineral-insulated, metal-sheathed cable.
- (8) Type MC cable where listed and identified for grounding in accordance with both of the following:
 - (a) The combined metallic sheath and grounding conductor of interlocked metal tape-type MC cable.
 - (b) The metallic sheath or the combined metallic sheath and grounding conductors of the smooth or corrugated tube type MC cable.

- (9) Cable trays as permitted by sections 392.3(c) and 392.7 of the code.
- (10) Cablebus framework as permitted by section 370.3 of the code.
- (11) Other **listed** electrically continuous metal raceways and **listed** auxiliary gutters ~~listed for grounding.~~
- (12) **Surface metal raceways listed for grounding.**

R 408.30873 **Uses permitted.**~~Fire alarm monitoring.~~

Rule 873.~~Section 760.11 is added to the code to read as follows:~~

~~760.11. The enforcing agency shall ensure that all fire protective circuits are electrically or electronically monitored for integrity so that any malfunction of the system, such as an electrical open, a ground fault, or any short circuit fault on the main power supply, signaling line, or alarm initiating devices or fire safety control circuit, will indicate a visual and audible signal at the alarm panel when proper alarm operation would be prevented.~~

~~Exception 1: Interconnecting circuits of household fire warning equipment that are wholly within a dwelling unit.~~

~~Exception 2: Fire safety control circuits that operate on loss of power to the auxiliary fire safety control relay are considered self monitoring for integrity.~~

Section 334.10 of the code is amended to read as follows:

334.10. Uses Permitted. Type NM, Type NMC, and Type NMS cables may be used in the following:

- (1) One- and 2-family dwellings.
- (2) Multifamily dwellings except as prohibited in section 334.12 of the code.
- (3) Other structures except as prohibited in section 334.12 of the code. In structures exceeding 1 floor above grade, cables shall be concealed within walls, floors, or ceilings that provide a thermal barrier of material that has at least a 15-minute finish rating as identified in listings of fire rated assemblies in accordance with the Michigan building code.
- (4) Cable trays in structures permitted to be Types III, IV, or V where the cables are identified for the use.